



"THE STANDARD OF EXCELLENCE IN THE INDUSTRY"

CASING SPACERS (Stainless Steel) - STYLE – CCS

Casing spacer shall be a two-piece shell per carrier pipe and made from T-304 stainless steel of a minimum 14 gauge thickness. Each shell section shall be lined with a 0.090" thick, ribbed PVC extrusion with a retaining section that overlaps the edges of the shell and prevents slippage. Bearing surfaces (runners) shall be ultra high molecular weight polyethylene (UHMW) to provide abrasion resistance and a low coefficient of friction (0.12). The runners shall be attached to support structures (risers) at appropriate positions to properly support the carrier pipe within the casing pipe and to ease installation. The runners shall be mechanically bolted to the riser. The bolt heads are welded to the inside of the risers for strength. Risers shall be made of T-304 stainless steel of a maximum 10 gauge. All risers shall be MIG welded to the shell. Bottom risers 6" and over in height shall be reinforced. All reinforcing plates shall be 10 ga. T-304 stainless steel and shall be MIG welded to mating parts. ***Standard positioning within the casing pipe*** shall be sized such that the carrier rests near the bottom of the casing pipe and the height of the risers and runners are to provide a bottom clearance not less than one-half inch between the casing pipe and the extreme outside diameter of the joint (bell, seam weld, joint clamp, ...) of the carrier pipe. ***Centered & Restrained positioning within the casing pipe*** shall be sized such that the height of the risers and runners are to center the carrier pipe in the casing pipe with a top clearance of three-fourths inch minimum. ***Restrained positioning within the casing pipe*** shall be sized such that the carrier rests near the bottom of the casing pipe and the height of the risers and runners are to provide a bottom clearance not less than one-half inch between the casing pipe and the extreme outside diameter of the joint (bell, seam weld, joint clamp, ...) of the carrier pipe and a top clearance of three-fourths inch minimum. ***Multiple Carrier pipes within the casing pipe*** shall be sized such that the carrier pipes are held at fixed distances relative to each other, with the height of the risers and runners to provide not less than three-fourths inch between the casing pipe and the outside diameter of the riser/runner combinations. Special reinforcing plates may be required to stabilize and support structure. All welds and metal surfaces shall be chemically passivated. Due to the numerous application possibilities, consult factory for spacing requirements. Casing spacers shall be Model CCS as manufactured by Cascade Waterworks Mfg. Co. of Yorkville, IL or approved equal.

02.01.2007

CASCADE WATERWORKS MANUFACTURING COMPANY

1213 Badger Street • Yorkville, IL 60560 • (630) 553-0840 • (800) 426-4301 • FAX (630) 553-0181

www.cascademfg.com