



"THE STANDARD OF EXCELLENCE IN THE INDUSTRY"

SERVICE SADDLE (Fabricated Steel w/ Stainless Steel Band) - STYLE – CFS

Service Saddle shall be made from a top shell section and a back shell section. The back shell section shall be T-304 stainless steel, with a minimum thickness of 14 gauge with bolt bars TIG welded to the shell. Each bolt bar shall be T-304 stainless steel of a minimum thickness 10 gauge. The top shell section (outlet side) shall be ASTM A 285 Grade C or ASTM A 36 steel, with a minimum thickness of 3/16 inch for pipe diameters between 6.00" and 12.50" and a minimum thickness of 3/8 inch thick for pipe diameters over 12.75", and have 3/8" thick mounting ears MIG welded to the shell. The outlet shall be ASTM A 285 Grade C or ASTM A 36 steel and attached to the Top shell with an outside seam MIG weld. The top shell shall have a virgin EPDM, broad throat outlet gasket to assure a positive seal. The Back shell section shall be attached to the Top shell section using Xylan coated 18-8 T-304 stainless steel heavy hex nuts. The washers shall be 18-8 T-304 stainless steel. The bolts shall 18-8 T-304 stainless steel and shall be 5/8-11 thread. All stainless steel weldments shall be passivated in accordance with ASTM A 380 and all carbon steel weldments on the saddle body to be finished with certified ANSI/NSF 61 epoxy coating. The tapping saddle shall be CFS series as manufactured by Cascade Waterworks Mfg. Co. of Yorkville, IL or approved equal.

TAPPING SADDLE w/ THREADED OUTLET (Fabricated Carbon Steel) - STYLE – CFT-TO

Tapping Saddle shall be made from a top shell section and a back shell section. The back shell section shall be ASTM A 285 Grade C or ASTM A 36 steel, with a minimum thickness of 3/16 inch for pipe diameters between 4.50" and 9.05" and a minimum thickness of 3/8 inch thick for pipe diameters over 9.05", and have lug bars MIG welded to the shell. Each lug bar shall be ASTM A 285 Grade C or ASTM A 36 steel of a minimum thickness of 1/4 inch, and are MIG welded along the top and bottom edges. The top shell section (outlet side) shall be ASTM A 285 Grade C or ASTM A 36 steel, with a minimum thickness of 3/16 inch for pipe diameters between 4.50" and 9.05" and a minimum thickness of 3/8 inch thick for pipe diameters over 9.05", and have lug bars MIG welded to the shell similar to the back shell. The outlet shall be ASTM A 285 Grade C or ASTM A 36 steel and attached to the Top shell with an outside seam MIG weld. The top shell shall have a virgin EPDM, compliant with ASTM D 2000 BA508, broad throat outlet gasket to assure a positive seal. The Back shell section shall be attached to the Top shell section using ASTM A 242 low alloy steel (or optional Xylan coated 18-8 T-304 stainless steel) heavy hex nuts. The washers shall be ASTM A 242 low alloy steel (or optional 18-8 T-304 stainless steel). The bolts shall made of low alloy steel meeting ASTM A 242 and AWWA C 111 ANSI A21.11 (or an optional 18-8 T-304 stainless steel) and shall be 3/4-10 thread, oval-neck track bolts. All metal surfaces on the saddle body to be finished with certified ANSI/NSF 61 epoxy coating. The tapping saddle shall be CFT-TO series as manufactured by Cascade Waterworks Mfg. Co. of Yorkville, IL or approved equal.

These specifications are accurate at time of publication and are subject to change without prior notice.

03.02.2011

CASCADE WATERWORKS MANUFACTURING COMPANY

1213 Badger Street • Yorkville, IL 60560 • (630) 553-0840 • (800) 426-4301 • FAX (630) 553-0181

www.cascademfg.com